

ANALOG BRUSHLESS PWM SERVO AMPLIFIERS SMA8115 3U PLUG-IN AMPLIFIER MODEL NUMBERING

ANALOG BRUSHLESS PWM SERVO AMPLIFIERS SMA8115 AMPLIFIER MODEL NUMBERING

This section explains the model numbering system for Glentek's SMA8115 Analog Brushless PWM servo amplifier. The model numbering system is designed so that you, our customer, will be able to quickly and accurately create the model number for the amplifier that best suits your needs. In order to accurately select a complete part number, please choose the industry standard mounting configuration which meets your needs (i.e. Module, 3U Plug-in, Stand-Alone or Multi Axis) and then complete the amplifier configuration code per your requirements.

Note: A complete model number example follows each section and includes a full description of the individual codes which make up the complete model number.

3U Plug-in Model Numbering

SMA8115XX - YYYY - QQQ - 3U

Amplifier Model Number _____

Power Rating _____

Omit = Standard Power

HP = High Power

Amplifier Configuration Code _____

_____ **3U Plug-in Single Module**

_____ **Optional Custom
Configuration Code.**

(A numerical code will be assigned by Glentek to amplifiers whose specifications vary from the standard configuration.)

Glentek, Inc.

208 Standard Street • El Segundo, California 90245 USA
(310) 322-3026 • (310) 322-7709 Fax • www.glentek.com

ANALOG BRUSHLESS PWM SERVO AMPLIFIERS SMA8115 3U PLUG-IN AMPLIFIER MODEL NUMBERING

LOGIC INPUT CONFIGURATION DESCRIPTION:

There are four logic inputs: Limit+, Limit-, Inhibit and Reset In. They may be configured for active-high or active-low signals and pull-up or pull-down termination (type A, B, C and D). All logic inputs have selectable 0 to +5VDC or 0 to +15VDC range. Following is a description of the various types (A, B, C and D) and how they apply to the inhibit input:


Type "A": Requires grounding of input to disable the amplifier (pull-up, active-low).

Type "B": Requires a positive voltage at input to disable the amplifier (pull-down, active-high).

Type "C": Requires grounding of input to enable the amplifier (pull-up, active-high).

Type "D": Requires a positive voltage at input to enable the amplifier (pull-down, active-low).

Amplifier Configuration Code



Example: SMA8115 - 1044 - 1

240-340VDC Operation, Type A Motor Temp.,
+15VDC Logic, Type A Reset, Type C Inhibit,
Type A Limits, Single-Ended Signal Input,
Current Mode, 120°/240° Sensor Select,
Motor Reverse Off

Single amplifier module